

City of Wichita, Kansas

Americans with Disabilities Act Transition Plan

Fire Station 13

44th Street North & Meridian

August 2005



Prepared by

DMCG

Disability Management Consulting Group L.L.C.

2801 Jonquil Place
Columbia, MO 65202

In conjunction with

The Great Plains ADA & IT Center and the City of Wichita Disability Advisory Board

City of Wichita – ADA/504 Transition Plan – Fire Station #13 - August 2005 Legend: **Blue** font identifies hyperlinked documents – **Red** font indicates recommended changes to structures or policies

Locations	Structural Inconsistencies		Recommended Corrections/Modifications to Ensure Program Access	Criteria – L=low, M=medium, H=high			Supplemental Technical Information			Finalized Actions		
Location	Identified Issue	ADAAG Specifications	Recommended Correction	Priority (overall)	Public Access	Frequency - PWD	Photo #	Conceptual Costs	Support Information	Finalized Correction	Date to be Corrected	Date Completed (Include initial)
1. Unisex Restroom	Braille and raised character signage does not exist at the entrance door.	4.1.3(16) 4.30.4	ADAAG requires public restrooms to be designated with Braille, raised letters, and the symbol of accessibility, where restrooms are accessible. Provide ADAAG compliant signage at restroom entrances.	L	L	M	1	\$50	Signage Specifications for Permanent Rooms and Spaces			
2. Unisex Restroom	The toilet is centered at 19-inches.	4.16	According to ADAAG, accessible water closets must be centered at 18-inches from the side wall. Move the toilet so it is centered at 18-inches or add substance to the sidewall so the toilet is centered at 18-inches.	L	L	M	3	\$500	Restroom Figures – Building Blocks			
3. Unisex Restroom	The toilet paper dispenser in not in the appropriate location.	4.16.6	According to ADAAG, toilet paper dispensers are required to be installed within reach, as shown in Fig. 29(b) . Move the toilet paper dispenser back toward the water closet to the point that it complies with ADAAG specifications.	L	L	M	3	\$50	Restroom Figures – Building Blocks			

Fire Station #13 - Conceptual Cost Projections

Total	\$600
Year One (Very High)	\$0
Year Three (High)	\$0
Year Five (Medium)	\$0
Year Ten (Low)	\$600